Slip Test Report – Batch Certification

National Ceramic Industries Australia Pty Ltd, ABN: 83 100 467 267					
175 Racecourse Rd, Rutherford NSW 2320, Australia, Tel: +61 2 4931 8400 Fax: +61 2 4931 8499, www.ncia.com.au					
Slip Resistance Classification of New Pedestrian Surfaces Materials Australia Standard AS 4586:2013 Appendix A (Wet Pendulum Test Method)					
Production Date	28/05/2022	**Test Sheet No:**	220530	**Issue Date**	0408/2023
Tile Name/s	Essential Stone White 450x450	**Code/s**	YES11545A	**Batch**	5052

Testing was conducted using a 96 rubber slider in accordance with the above Standard.
Slider was prepared/conducted using P400C paper and 3 µm lapping film

Reference	Test Location	Cleaning Pre-testing	Results of Last three Swings British Pendulum Number (BPN)			Mean BPN	Classification of Pedestrian Surfaces Materials according to the above Standard
YES11545A	Tile Surface	Water & Scrubbing	46	46	46	46	**P4**
Temperature (indoor)	21.1°C	Mean BPN Slip Resistance Value (SRV)				46	
Testing Instrument	Pendulum Friction Tester, Calibration Date: 02 November 2021				National Ceramic Industries Australia Pty Ltd		
Reporting Officer	Hong Lu				NCIA Tiles Testing Laboratory		

stoneworld
NATIONWIDE TILES & SURFACES

1st August 2023

TO WHOM IT MAY CONCERN

Re : SLIP RESISTANCE CLASSIFICATION REPORT – Essential Stone 450 x 450 Structured

Dear Sir / Madam,

Please find attached the Slip Resistance Classification Report for the Stoneworld tile, Essential Stone Structured.

Please be aware that the attached test results are from the batch of tiles that were available at the time of testing. These test results are provided as an indication of slip rating as the slip rating may vary for each batch of tiles. Stoneworld provides slip rating test results as a guide ONLY and takes no responsibility for the slip rating of any non-tested batches, nor is it liable for any costs incurred in any further testing or re-testing of tiles.

The test result of tiles may change subsequent to delivery, through the laying process, during the completion of the building work, or through wear and tear.

Regards,

Alan Williams

GROUP NATIONAL MANAGER

10 YEAR WARRANTY