



Floor Testing Australia

PO Box 2311
 Redcliffe Qld 4020
 P: 0403 284 789
 E: admin@floortestingaustralia.com.au
 www.floortestingaustralia.com.au
 ABN: 24 166 057 174

Customer Name:	Q.L.I
Address:	3345 Pacific Highway Slacks Creek. 4127
Tile Identification:	GIV6S1314 60cm X 60cm
OPERATOR:	Ivan J Cindric
DATE:	February 2, 2017
SLIP TESTER CALIBRATION No:	BS796-3 JobR15/9184
SLIP TESTER SERIAL No:	SK 1710
SLIDER TYPE & CERTIFICATE No:	#96 – Batch 53 (4 S Rubber)
CONTAMINATE DESCRIPTION:	Water

Certificate of Pendulum Test Results:

Condition	Pendulum Test Values (PTV)
Wet	Mean Wet PTV: 29 SA HB198:2014 = Class: P2 - Y

The table below states the Slip Potential classifications from Pendulum Test Values (PTV).

CLASS	Pendulum Mean (BPN) Four S rubber
P5 - V	> 54
P4 - W	45-54
P3 - X	35-44
P2 - Y	25-34
P1 - Z	13-24
P0 - Z	<12

RATING AS PER AUSTRALIAN STANDARD 4586-2013 / HB197:1999

Ivan J Cindric

Ivan J Cindric
 Floor Testing Australia