



中国认可
国际互认
检测
TESTING
CNAS L1978

国家建筑卫生陶瓷检测重点实验室
STATE KEY TESTING LABORATORY OF BUILDING CERAMICS AND SANITARY WARE
佛山海关综合技术中心
COMPREHENSIVE TECHNOLOGY CENTRE OF FOSHAN CUSTOMS

检测报告 TEST REPORT

报告编号:

Test report No.: **25202603799**

共 1 页, 第 1 页

Page 1 of 1

委托单位:

佛山市鸿富陶瓷有限公司

Applicant:

HERITAGE CERAMICS (APAC) PTE LTD

委托单位地址:

佛山市禅城区石湾街道跃进路 148 号 7 幢之一 (1 楼)

Address of Applicant:

1ST FLOOR, BLOCK 7-1, NO.148, YUEJIN ROAD, CHANCHENG FOSHAN

样品名称:

釉面砖

Name of Sample:

GLAZED PORCELAIN

样品记号:

MILLENNIA IVORY MATT

Mark of Samples:

样品规格:

Sizes of Sample:

600mm × 600mm

样品来源:

委托单位自送样品

样品数量:

4 片

Source of Samples:

Samples selected by applicant

Quantity of Samples:

4 Pieces

接样日期:

6 JAN 2026

检测日期:

Test Date:

6 JAN 2026

检测依据:

Test Standard:

AS 4586-2013/Amdt 1-2017 *Slip resistance classification of new pedestrian surface materials*

检测结果:

Test Results:

检测项目 Test Item	检测方法 Test Method	检测结果 Test Results
防滑性能, 摆锤法, 湿法, Slider 96 Slip resistance, Wet pendulum test method, Slider 96	AS 4586-2013/Amdt 1-2017 Appendix A 附录 A	SRV:40 类别 Class: P3

*备注: AS 4586-2013/Amdt 1-2017 要求试样的数量不少于 5 件, 实际测试的试样数量为 4 件。

*Note: AS 4586-2013/Amdt 1-2017 requires a minimum of five specimens to be tested for a classification to be given, only four specimen tested based on the procedure set out in AS 4586-2013/Amdt 1-2017, therefore results are indicative only.

*** **

报告结束 End of Test Report

检测单位盖章

Stamp of test unit

授权签字人:

Authorized Signatory

肖景红

XIAO JINGHONG

日期: 2026-01-10

Date



声明: 1、我们已尽所知所能实施上述检测, 不能因签发本报告而免除有关各方根据合同和法律所承担的责任和义务; 2、未经本实验室书面许可, 不得部分复制本报告; 3、本报告仅是样品的检测结果;

4、本报告所述的样品信息为委托单位自行声明, 实验室不负责其真实性。

Notes: 1. All tests are carried out conscientiously to the best of our knowledge and ability. This report does not in any respect absolve the other related parties from his contractual and legal obligations.

2. This report shall not be reproduced, except in full, without the prior written approval from the issuing laboratory. 3. The results in this report apply to the samples only. 4. The product information is declared by applicant, and laboratory is not responsible for the authenticity.

广东省佛山市禅城区魁奇一路澜石(国际)金属交易中心十八座二楼 2/F, Building 18, Lanshi International Metal Exchange Center, Kuiqi Road, Chancheng District, Foshan, Guangdong, China 528000

Tel: 86-757-83960558 83827991 E-mail: fsiqtc@163.com

RZE-T 1(2)